

1. FIRE SEPARATION BETWEEN GARAGE AND HOUSE OR PORCHES SHALL BE CONSIDERED AS A WALL. THE GROUND FLOOR AND SEPARATE UNIT IS MEANT TO ENCLOSURE WITH MINIMUM 10 CM THICK BRICKWORK OR EQUIVALENT. SELF-CLOSING DOOR OR EQUAL, ALL DOORS WILL BE SELF-CLOSING, WEATHER STRIPPED AND HAVE A POSITIVE LATCH, ARE NON-APPROVED NON-METALLIC PENETRATIONS ARE ALLOWED SEPARATING WALL SHALL BE CONSIDERED AS AN EXTERIOR WALL.
2. SMOKE DETECTORS SHALL RECEIVE THEIR PRIMARY POWER FROM THE BUILDING MAINS AND SHALL BE EQUIPPED WITH BATTERY BACKUP. DETECTORS SHALL BE AUDIBLE IN ALL SLEEPING AREAS OF THE DWELLING, AND ALL SMOKE DETECTORS SHALL BE INTERCONNECTED.
3. KITCHEN LIGHTING TO HAVE AN EFFICACY OF AT LEAST 40 LUMENS PER WATT, I.E. FLUORESCENT, AND CONTROLLED BY THE MOST ACCESSIBLE SWITCHES) IN THE KITCHEN.
4. FULL BATH MUST HAVE AT LEAST ONE LUMINAIRE WITH LAMPS WITH AN EFFICACY OF AT LEAST 40 LUMENS PER WATT, I.E. FLUORESCENT.
5. ALL GAS FIRED EQUIPMENT IN GARAGE, WHICH HAVE TO ACCOMMODATE OTHER TAIL MODEL #960, TESTED TO CSA STANDARD C227-113 MAY 1984.
6. ALTHOUGH SPRINKLER DEVICES ARE REQUIRED AT ALL HOSE BIBBS, MIN ONE BACK AND ONE FRONT OF STRUCTURE, THIS IS TO PREVENT THE POSSIBLE PORTABLE WATER SYSTEM INTO THE STRUCTURE WATER SYSTEM
10. MECHANICAL DUCTS CAPABLE OF PERFORMING (A) CAN CHANGES PER HOUR.
11. PLUMBING FIXTURES AND PLUMBING FITTINGS SHALL MEET THE FOLLOWING:  
2.2 GPM /FLUSH MAX  
WATER CLOSERS  
AND SINK FAUCETS  
SHOWER HEADS 2.5 GPM MAX
12. ALL RECEPTACLE OUTLETS INSTALLED IN BEDROOMS TO BE PROTECTED BY AN ARC-FAULT CIRCUIT INTERRUPTER.
13. FLUSH MOUNT, FULLY ENCLOSED INCANDESCENT LIGHT, INSULATION COVER (IC) AND BE AIRTIGHT (A.T).
14. ALL GAS FIRED EQUIPMENT IN GARAGE, WHICH HAVE TO ACCOMMODATE OTHER TAIL MODEL #960, TESTED TO CSA STANDARD C227-113 MAY 1984.